



Certificate of Boiler Efficiency

The Fröling PE1 Pellet Boiler line has been tested in accordance with EPA 2020 regulations using test method ASTM 2618-13 by Research Institutes of Sweden AB, an EPA accredited independent laboratory.

EPA seasonal average efficiency (HHV) has been determined to be 78% for the Model 20 and 80% for the model 35. Maximum tested efficiency is 86% HHV for the PE1 20 and 87.2% HHV for the PE1 35.

Under penalties of perjury, I declare that I have examined this certification statement, and to the best of my knowledge and belief, the facts are true, correct, and complete.

Scott W. Nichols
President

19 Archertown Rd. | PO Box 322 | Orford, NH 03777 | 800.782.9927 | 603.795.9100
www.tarmusa.com | info@tarmusa.com

March 2021